

TRUELOVE PLUMBING CO. INC.

3522 NORTH SWING ST.
KINGMAN, AZ 86409
PH (928) 757-4892 FAX (928) 757-7214
Email trueloveplumbing2@frontiernet.net

PROPOSAL

8/12/13

TO: PEACH SPRINGS UNIFIED SCHOOL DISTRICT

ATTN: GARY

RE: LP GAS LINE REPAIRS AND REROUTE @ SCHOOL LOCATED AT 403 DIAMOND CREEK RD.

PH: 279-4263

FAX: 769-2852

INCLUDES LABOR AND MATERIAL FOR THE FOLLOWING:

ORIGINAL TESTING AND TROUBLE SHOOTING TO DETERMINE ISSUES.

1-UNDERGROUND MEDIUM PRESSURE (2 TO 10 PSI) 1-1/2" LP GAS LINE PIPED IN HDPE WITH 2 STEEL TRANSITION RISERS, TRACER WIRE AND CAUTION TAPE RAN FROM THE TANK LOCATION TO THE NORTH WEST SIDE OF THE BLDG. THE LINE WILL TEE ABOVE GROUND AT THE RISER FOR THE TANKS AND HAVE TWO ISOLATION BALL VALVES FOR CONNECTION BY THE LP PROVIDER TO THE TANKS. THE BLDG RISER WILL HAVE AN ISOLATION VALVE AND A UNION CONNECTION TO THE BLDG PIPING.

1-EXPOSED MEDIUM PRESSURE LP GAS LINE PIPED IN SCHEDULE 40 BLACK IRON T&C FROM THE GROUND RISER UP THE OUTSIDE OF THE BLDG, ACROSS THE ROOF ON TREATED BLOCKS (TYP OF ALL) TO THE WATER COLUMN REGULATOR (PROVIDED AND INSTALLED BY THE LP PROVIDER)

1-EXPOSED LOW PRESSURE (11" WATER COLUMN) LP GAS LINE PIPED IN 2-1/2" BLK IRON T&C FROM THE WATER COLUMN REGULATOR TO THE POINT OF CONNECTION ON THE LOWER ROOF ABOVE THE CLASS ROOMS THAT SERVES 13 FAUS.

1-EXPOSED LOW PRESSURE LP GAS LINE PIPED (TYP) IN 2" FROM THE REGULATOR TO THE WATER HEATER, KITCHEN EQUIPMENT POC IN THE WATER HEATER ROOM AND 3 FAUS ABOVE THE KITCHEN AREA.

1-EXPOSED LOW PRESSURE LP GAS LINE PIPED (TYP) IN 2" FROM THE REGULATOR TO THE POC FOR THE LINE FEEDING THE FAUS ABOVE THE GYM.

1-EXPOSED LOW PRESSURE LP GAS LINE PIPED (TYP) IN 1-1/4" FROM THE LOWER ROOF PIPING TO THE NEW LP GENERATOR LOCATION WITH ISOLATION VALVE.

EXCLUSIONS:


PERMIT FEES
EXCAVATION AND BACKFILL
ENGINEERING
PAINTING
PROVIDING AND INSTALLING LP REGULATORS
CONCRETE

SUBTOTAL	\$15,883.00
SALES TAX	\$883.27
TOTAL	\$16,766.27

RESPECTFULLY SUBMITTED BY:


PAT YARUSH / ESTIMATOR

AUTHORIZED SIGNATURE:

 DATE: 8/13/13



TRUE LOVE PLUMBING CO., INC.

 3522 North Swing
 KINGMAN, ARIZONA 86409
 (928) 757-4892

JOB INVOICE

39433

8:00 Raul

CUSTOMERS ORDER NO.		DATE ORDERED	
		8-6-13	
ORDER TAKEN BY		DATE PROMISED <input type="checkbox"/> A.M. <input type="checkbox"/> P.M.	
BILL TO		PHONE	
TEACH SPRINGS U.S.D.		379-4263	
ADDRESS		MECHANIC	
CITY		HELPER	
JOB NAME AND LOCATION		<input type="checkbox"/> DAY WORK	
ELEMENTARY School		<input type="checkbox"/> CONTRACT	
DESCRIPTION OF WORK		<input type="checkbox"/> EXTRA	
GAS LEAKS @ MAIN			
2 1/2" PIPE			

QUANT.	DESCRIPTION OF MATERIAL USED	PRICE	AMOUNT
	CHECK FOR GAS LEAK		9.95
1	3/4 BALL VALVE		
-	UNDERGROUND LINE LOOSES		
	6 LBS EVERY 20 MIN. @		
	EXISTING 20 PSI LP PRESSURE		
-	FOUND 9 LEAKS @ ABOVE GROUND		
	LINE - 5 @ W.H. AREA &		
	4 ON ROOF. RECOMMEND		
	REPIPE FOR FAILING AREAS.		
	OLD PIPE IS CORRODED. SEE PROPOSAL		
7	HRS ON 8-7-13		
	RAUL		
	BILLY		
1 1/2	HRS ON 8-9-13		
	RAUL		
	BILLY		

HOURS	LABOR	AMOUNT	TOTAL MATERIALS	TOTAL LABOR	mileage	TAX	TOTAL
13 1/2	MECHANICS Raul @ 70-	945-	9.95	1687.50	150	-83	1848.28
13 1/2	HELPERS Billy @ 55-	742.50					
I hereby acknowledge the satisfactory completion of the above described work.		TOTAL LABOR	1687.50	TAX	-83		
SIGNATURE		DATE COMPLETED	8/9/13	TOTAL	1848.28		